

A new class of model-based static estimators

Maryam Ghadrdan, Chriss Grimholt, and Sigurd Skogestad*

Department of Chemical Engineering, Norwegian University of Science and Technology, N-7491

Trondheim, Norway

E-mail: skoge@nt.ntnu.no

Abstract

Static estimators are commonly used as "soft-sensors" in the process industry. The performance of the estimators depend on whether it is used for monitoring (open-loop) or for closed-loop control applications. In this work, we propose to design estimators specialized for each case. The approach is to minimize the estimation error for expected disturbances and measurement noise. The main extension compared to previous work is to include measurement noise and to provide explicit formulae for computing the optimal static estimator. We also compare the results with standard existing estimators, e.g. PLS. The approach is applied to estimation of product composition in a distillation column from combination of temperature measurements.

Introduction

In a chemical plant, there are usually a large number of sensors which are used for monitoring and control of processes. However, some process variables (e.g., composition) may be too difficult or expensive to measure online. Estimators, also called soft sensors, work by predicting such variables using available measurements (e.g. temperatures).

*To whom correspondence should be addressed

Both dynamic and static estimators may be used, but the simpler static estimators are most common in the process industry. Since our method is a static estimator, our literature survey is limited to this group. There are many approaches that have been used to obtain the static estimators, including multivariate regression,^{1,2} artificial neural networks,³ support vector machine regression,⁴ etc.

Principle Component Regression (PCR)⁵ and Partial Least Squares (PLS)⁶ are two of the most used data analysis tools in chemometrics. These methods are based on projecting the solution to a lower-dimensional subspace. The literature review by Wentzell and Montoto compared these two methods, covering both experimental and simulation studies.⁷ In short, the advantage of PLS is that the method obtains a small prediction error with fewer principal components than for PCR. Because of the popularity of these methods, we are going to compare our method with the PLS regression method.

The simplest model-based static estimator is the "inferential estimator" of Brosilow and coworkers.⁸ Let $\tilde{u} = \begin{bmatrix} u & d \end{bmatrix}$ represent the vector of independent variables, including the inputs u and the disturbances d . Let x represent the process measurements and y the variables we want to estimate. Let the linear static model in deviation variables be

$$x = \mathbf{X}\tilde{u} \tag{1}$$

$$y = \mathbf{Y}\tilde{u} \tag{2}$$

The "Brosilow" estimator is then simply the following least squares estimate of y

$$\hat{y} = \mathbf{H}x_m \tag{3}$$

where

$$\mathbf{H} = \mathbf{Y}\mathbf{X}^\dagger \tag{4}$$


and \mathbf{X}^\dagger is the pseudo inverse of the matrix \mathbf{X} .

Joseph and Brosilow⁸ discuss some of the weaknesses of this estimator. For "ill-conditioned" plants with large condition number of \mathbf{X} , they find that the estimate may be improved in some cases by removing measurements, because this reduces the condition number. Intuitively, removing measurements cannot be the optimal way of dealing with these problems, because we are throwing away information. This is also clear when we consider the popular "data-based" regression estimators, like Partial Least Squares (PLS) regression,⁹ where one does not remove measurements, but instead removes weak "directions" in the data.


A fundamental problem with the Brosilow inferential estimator is that it fails to take into account measurement noise in an explicit manner. The main goal of this paper is to include the effect of measurement noise in the derivation of the optimal model-based static estimator. This means that we handle in an optimal manner the "high condition number problem", which has been a major concern in previous work.^{1,8,10-12} The derivation is straightforward, but surprisingly it seems it has not been presented before.

Another issue is that the Brosilow least squares estimator does not take into account whether the estimator is used only for monitoring or for closed-loop operation. Actually, the latter is a shortcoming of most existing data-based estimators. In the paper, we derive optimal estimators for four cases as illustrated in Figure 1. Case S1 is the direct extension of the Brosilow inferential estimator to include measurement noise. In case S2, the inputs u are used to control the variables y at given setpoint y_s . It is similar to case S1, except that the setpoint y_s takes the role of the inputs. Case S3 is a generalization where we control the variables z . Cases S1, S2 and S3 are practically relevant if the estimator is used for monitoring only, because the estimate \hat{y} is not used for control. Finally, case S4 is the relevant case when we use the estimator in closed loop (for control purposes). Whereas the optimal estimators for cases for cases S1, S2 and S3 are least-square estimators with a similar structure to the Brosilow estimator in (4), the structure for case S4 is quite different and the mathematics to derive it are more complex. The derivation is based on results for optimal measurement combination for self-optimizing control¹³ and is the main new contribution of this paper.


The derivation of the new static estimators is presented in section 2. The concept of some well-known data-based estimators are described in section 3. In section 4 we discuss how we can use our new ideas for optimal model-based to derive new data-based estimator. Finally, in section 5, we compare the new static estimators with previous work, including the Brosilow estimator and regression based estimators on distillation case-studies.




(a) S1: Monitoring case where u is a free variable



(b) S2: Monitoring case where u is used to control the primary variable y



(c) S3: Monitoring case where u is used to control the secondary variable z



(d) S4= CL: "closed-loop" case where u is used to control the predicted variable \hat{y}

Figure 1: Block diagrams for different cases

Derivation of Model-based Static Estimators

Problem definition

We define the following variables:

- u : inputs (degrees of freedom); these may include setpoints to lower-layer controllers
- d : disturbances, including parameter changes.
- x : all available measured variables.
- n^x : measurement noise (error) for x .
- y : primary variables that we want to estimate
- z : secondary variables, which we may control, $\dim(z) = \dim(u)$

All variables are assumed to be deviation variables (away from the nominal or centered values). In this section, we derive optimal "open-loop" and "closed-loop" static estimators. By "optimal", it is meant that we for a linear estimator of the form

$$\hat{y} = \mathbf{H}x_m \tag{5}$$

want to minimize the expected prediction error

$$e = y - \hat{y} \tag{6}$$

The measurement signals x_m , corrupted by measurement noise n^x , are

$$x_m = x + n^x \tag{7}$$

We use linear static models for the primary variables y , measurements x , and secondary variables z (see Figure 2)

$$y = \mathbf{G}_y \mathbf{u} + \mathbf{G}_y^d \mathbf{d} \quad (8)$$

$$x = \mathbf{G}_x \mathbf{u} + \mathbf{G}_x^d \mathbf{d} \quad (9)$$

$$z = \mathbf{G}_z \mathbf{u} + \mathbf{G}_z^d \mathbf{d} \quad (10)$$

In terms of the notation used for the Brosilow inferential estimator in (1) we have

$$\mathbf{X} = \begin{bmatrix} \mathbf{G}_x & \mathbf{G}_x^d \end{bmatrix} \quad (11)$$

$$\mathbf{Y} = \begin{bmatrix} \mathbf{G}_y & \mathbf{G}_y^d \end{bmatrix} \quad (12)$$




Figure 2: Block diagram for the linearized plant

In addition, the expected magnitude variables of the independent variables for each case (see Figure 1) is quantified by weighting matrices (\mathbf{W}_u , \mathbf{W}_d , \mathbf{W}_{n^x} , \mathbf{W}_{y_s} , \mathbf{W}_{z_s}), as explained in detail below.

Estimators used for monitoring (cases S1, S2 and S3)

With the term “open-loop”, it is implied that the predicted variables $\hat{y} = \mathbf{H}x_m$ are used for monitoring, that is, they are not used for control purposes. It should be noted that this is not the same as implying that the variables in a given system are uncontrolled. We can think of three main types of open-loop monitoring estimators are illustrated in Figure 1:

Case S1. Predicting primary variables from a system with no control, i.e. the inputs u are free variables.

Case S2. Predicting primary variables from a system where the primary variables y are measured and controlled, i.e. the inputs u are used to keep $y = y_s$.

Case S3. Predicting primary variables from a system where the inputs u are used to control the secondary variables z , i.e. $z = z_s$.

We first consider case S1 in detail. Cases S2 and S3 are then straightforward extensions.

Case S1

Case S1 is the direct extension of the Brosilow estimator to include noise. To find the optimal estimator for open-loop operation, the prediction error has to be expressed as a function of the system and the estimator.

Lemma 1. *For a given linear estimator, when applied to the system defined in equations (5)-(9), and considering that u is a free variable, the prediction error can be expressed as*

$$e(\mathbf{H}) = \begin{bmatrix} (\mathbf{G}_y - \mathbf{H}\mathbf{G}_x) & (\mathbf{G}_y^d - \mathbf{H}\mathbf{G}_x^d) & -\mathbf{H} \end{bmatrix} \begin{bmatrix} \mathbf{u} \\ \mathbf{d} \\ \mathbf{n}^x \end{bmatrix} \quad (13)$$

Proof. An expression of \hat{y} as a function of u , d and \mathbf{n}^x can be obtained by substituting equations (7) and (9) into equation (5).

$$\hat{y} = \mathbf{H} \left(\mathbf{G}_x \mathbf{u} + \mathbf{G}_x^d \mathbf{d} + \mathbf{n}^x \right)$$

Using the definition of prediction error and substituting the expression for \hat{y} , we will have

$$e(\mathbf{H}) = (\mathbf{G}_y - \mathbf{H}\mathbf{G}_x) \mathbf{u} + (\mathbf{G}_y^d - \mathbf{H}\mathbf{G}_x^d) \mathbf{d} - \mathbf{H}\mathbf{n}^x$$

which is the same as equation (13).

Q.E.D.

Next, we derive an expression for the expected prediction error, assuming that \mathbf{u} , \mathbf{d} , \mathbf{n}^x are normally distributed with given weight matrices.

Lemma 2. Expected prediction error. *Let the disturbance and noise be normalized on the form*

$$\mathbf{u} = \mathbf{W}_u \mathbf{u}'$$

$$\mathbf{d} = \mathbf{W}_d \mathbf{d}'$$

$$\mathbf{n}^x = \mathbf{W}_{n^x} \mathbf{n}^{x'}$$

where the elements u' , d' and $n^{x'}$ of the normalized vectors \mathbf{u}' , \mathbf{d}' are assumed to be normally distributed with zero mean and unit standard deviation;

$$u' \sim \mathcal{N}(0, 1)$$

$$d' \sim \mathcal{N}(0, 1)$$

$$n^{x'} \sim \mathcal{N}(0, 1)$$

The diagonal scaling matrices \mathbf{W}_u , \mathbf{W}_d and \mathbf{W}_{n^x} contain the standard deviations of the elements in \mathbf{u} , \mathbf{d} and \mathbf{n}^x respectively.

From Lemma 1 the prediction error can be expressed as

$$e = \underbrace{\begin{bmatrix} (\mathbf{G}_y - \mathbf{H}\mathbf{G}_x) \mathbf{W}_u & (\mathbf{G}_y^d - \mathbf{H}\mathbf{G}_x^d) \mathbf{W}_d & -\mathbf{H}\mathbf{W}_{n^x} \end{bmatrix}}_{\mathbf{M}(\mathbf{H})} \begin{bmatrix} \mathbf{u}' \\ \mathbf{d}' \\ \mathbf{n}^{x'} \end{bmatrix}$$

The expected value of the 2-norm of the prediction error (variance) then becomes

$$E(\|e\|_2) = \|\mathbf{M}(\mathbf{H})\|_F^2$$

Proof. Let $\tilde{\mathbf{d}} = \begin{bmatrix} \mathbf{u}' \\ \mathbf{d}' \\ \mathbf{n}^{x'} \end{bmatrix}$. Then, $\mathbf{e} = \mathbf{M}\tilde{\mathbf{d}}$, and noting that $\|\mathbf{e}\|_2 = \text{tr}(\mathbf{e}\mathbf{e}^T)$, the expected value of the 2-norm of the prediction error can be written as

$$\begin{aligned} E(\|\mathbf{e}\|_2) &= E[\text{tr}(\mathbf{M}\tilde{\mathbf{d}}\tilde{\mathbf{d}}^T\mathbf{M}^T)] \\ &= E[\text{tr}(\mathbf{M}^T\mathbf{M}\tilde{\mathbf{d}}\tilde{\mathbf{d}}^T)] \\ &= \text{tr}(\mathbf{M}^T\mathbf{M}E[\tilde{\mathbf{d}}\tilde{\mathbf{d}}^T]) \end{aligned}$$

where $\text{tr}(\cdot)$ denotes the trace of the matrix and $E[\cdot]$ is the expectation operator.

Since $\left\| \begin{bmatrix} \mathbf{u}' \\ \mathbf{d}' \\ \mathbf{n}^{x'} \end{bmatrix} \right\| \sim \mathcal{N}(0, \mathbf{I}_{n_u+n_d+n_x})$, by substituting the normal distribution in the definition of expected value we have

$$E[\tilde{\mathbf{d}}\tilde{\mathbf{d}}^T] = \text{Var}(\tilde{\mathbf{d}})$$

In addition, we know that the square root of the trace of the matrix $\mathbf{M}^T\mathbf{M}$ is actually the definition of Frobenius norm of matrix \mathbf{M} . So,

$$E(\|\mathbf{e}\|_2) = \text{tr}(\mathbf{M}^T\mathbf{M}) = \|\mathbf{M}\|_F^2$$

Q.E.D.

From Lemma 2, the expected value of the 2-norm prediction error (variance) is minimized by selecting \mathbf{H} to minimize $\|\mathbf{M}\|_F$. This leads to the following theorem

Theorem 1. *The optimal "open-loop" estimator following the linear relationship*

$$\hat{\mathbf{y}} = \mathbf{H}\mathbf{x}_m$$

that minimizes the variance of the prediction error (Lemma 1 and 2)

$$\mathbf{e} = \mathbf{y} - \hat{\mathbf{y}}$$

when u is a free variable, is

$$\mathbf{H}_1 = \mathbf{Y}_1 \mathbf{X}_1^\dagger \quad (14)$$

where \mathbf{X}^\dagger is the pseudo-inverse of \mathbf{X} , and

$$\begin{aligned} \mathbf{Y}_1 &= \begin{bmatrix} \mathbf{G}_y \mathbf{W}_u & \mathbf{G}_y^d \mathbf{W}_d & 0 \end{bmatrix} \\ \mathbf{X}_1 &= \begin{bmatrix} \mathbf{G}_x \mathbf{W}_u & \mathbf{G}_x^d \mathbf{W}_d & \mathbf{W}_{n^x} \end{bmatrix} \end{aligned} \quad (15)$$

If \mathbf{X}_1 has full column rank, we have $\mathbf{X}_1^\dagger = (\mathbf{X}_1^T \mathbf{X}_1)^{-1} \mathbf{X}_1^T$. If \mathbf{X}_1 has full row rank, we have $\mathbf{X}_1^\dagger = \mathbf{X}_1^T (\mathbf{X}_1 \mathbf{X}_1^T)^{-1}$. For the general case, where \mathbf{X}_1 has neither full row nor column rank, the pseudo-inverse may be obtained using the singular value decomposition

Proof. In Lemma 2, we showed that minimizing $\|\mathbf{e}(\mathbf{H})\|_2$ is equivalent to minimizing $\|\mathbf{M}(\mathbf{H})\|_F^2$ for the expected prediction error. $\mathbf{M}(\mathbf{H})$ can be rewritten as

$$\mathbf{M} = \mathbf{Y}_1 - \mathbf{H} \mathbf{X}_1$$

The optimization problem then becomes

$$\min_{\mathbf{H}} \|\mathbf{Y}_1 - \mathbf{H} \mathbf{X}_1\|$$

and we recognize that this is the least squares problem with the known optimal solution.

$$\mathbf{H}_1 = \mathbf{Y}_1 \mathbf{X}_1^\dagger$$

Q.E.D.

Figure 3 shows an interpretation of Theorem 1, which is a direct generalization of the Brosilow estimator, when we also include noise. Note that the elements in \mathbf{Y}_1 corresponding to $\mathbf{n}^{x'}$ is zero.




Figure 3: Interpretation of Theorem 1

This estimator is optimal for the case where the process input \mathbf{u} are truly independent variables, that is, when we have no control (case S1 in Figure 1).

Case S2

We now consider the case where the inputs \mathbf{u} are used to keep the outputs \mathbf{y} at given setpoints \mathbf{y}_s . This means that \mathbf{y}_s replaces \mathbf{u} as independent variables. It is assumed that $\dim(\mathbf{y}) = \dim(\mathbf{u})$.

Theorem 2. *The optimal “open-loop” estimator \mathbf{H} for closed-loop operation, where the degrees of freedom \mathbf{u} are adjusted such that the primary variables \mathbf{y} are kept at the setpoints \mathbf{y}_s , that minimizes the variance of the prediction error $\mathbf{y} - \hat{\mathbf{y}}$ for normally distributed setpoint changes, disturbances and noise (of magnitudes \mathbf{W}_{y_s} , \mathbf{W}_d and \mathbf{W}_{n^x} respectively) is*

$$\mathbf{H}_2 = \mathbf{Y}_2 \mathbf{X}_2^\dagger$$

where

$$\mathbf{Y}_2 = \begin{bmatrix} \mathbf{W}_{y_s} & 0 & 0 \end{bmatrix}$$

$$\mathbf{X}_2 = \begin{bmatrix} \mathbf{G}_x^{cl} \mathbf{W}_{y_s} & \mathbf{F} \mathbf{W}_d & \mathbf{W}_{n^x} \end{bmatrix} \quad (16)$$

where $\mathbf{G}_x^{cl} = \mathbf{G}_x \mathbf{G}_y^{-1}$ and $\mathbf{F} = \mathbf{G}_x^d - \mathbf{G}_x \mathbf{G}_y^{-1} \mathbf{G}_y^d$

Proof. We assume that u is used to keep $y = y_s$ (with no control error). Solving equation (8) with respect to u when $y = y_s$ gives

$$u = \mathbf{G}_y^{-1}y_s - \mathbf{G}_y^{-1}\mathbf{G}_y^d d$$

By combining equations (9), (7) and (5) with the above equation, the following expression for \hat{y} as an explicit function of y_s , d and n^x is obtained,

$$\hat{y} = \mathbf{H} \left[\mathbf{G}_x \mathbf{G}_y^{-1} y_s + \left(\mathbf{G}_x^d - \mathbf{G}_x \mathbf{G}_y^{-1} \mathbf{G}_y^d \right) d + n^x \right]$$

Here, $\left(\mathbf{G}_x^d - \mathbf{G}_x \mathbf{G}_y^{-1} \mathbf{G}_y^d \right) = \left(\frac{\partial x}{\partial d} \right)_{y=y_s}$ is the optimal sensitivity \mathbf{F} ,¹³ and $\mathbf{G}_x \mathbf{G}_y^{-1} = \left(\frac{\partial x}{\partial y_s} \right)_d$ is known as the closed-loop gain \mathbf{G}_x^{cl} . So, the above equation becomes

$$\hat{y} = \mathbf{H} \left[\mathbf{G}_x^{cl} y_s + \mathbf{F} d + n^x \right]$$

With the assumption that $y = y_s$, the prediction error becomes

$$e = y - \hat{y} = \begin{bmatrix} (\mathbf{I} - \mathbf{H}\mathbf{G}_x^{cl}) & -\mathbf{H}\mathbf{F} & -\mathbf{H} \end{bmatrix} \begin{bmatrix} y_s \\ d \\ n^x \end{bmatrix}$$

Proceeding analogous to Lemmas 1 and 2 and Theorem 1, using $y_s = \mathbf{W}_s y'_s$ results in the given preposition. Q.E.D.

Case S3

The following theorem generalizes theorems 1 and 2.

Theorem 3. *The optimal “open-loop” estimator \mathbf{H} for closed-loop operation where the degrees of freedom u are adjusted such that the secondary variables z are kept at the setpoints z_s , that minimizes the variance of the prediction error $y - \hat{y}$ for normally distributed setpoint changes,*

disturbances and noise (of magnitudes \mathbf{W}_{z_s} , \mathbf{W}_d and \mathbf{W}_{n^x} respectively) is

$$\mathbf{H}_3 = \mathbf{Y}_3 \mathbf{X}_3^\dagger$$

where

$$\mathbf{Y}_3 = \begin{bmatrix} \mathbf{G}_y^{cl} \mathbf{W}_{z_s} & \mathbf{F}'_y \mathbf{W}_d & \mathbf{0} \end{bmatrix}$$

$$\mathbf{X}_3 = \begin{bmatrix} \mathbf{G}_x^{cl} \mathbf{W}_{z_s} & \mathbf{F}'_x \mathbf{W}_d & \mathbf{W}_{n^x} \end{bmatrix}$$

where $\mathbf{G}_y^{cl} = \mathbf{G}_y \mathbf{G}_z^{-1}$, $\mathbf{G}_x^{cl} = \mathbf{G}_x \mathbf{G}_z^{-1}$, $\mathbf{F}'_y = \mathbf{G}_y^d - \mathbf{G}_y \mathbf{G}_z^{-1} \mathbf{G}_z^d$ and $\mathbf{F}'_x = \mathbf{G}_x^d - \mathbf{G}_x \mathbf{G}_z^{-1} \mathbf{G}_z^d$

Proof. We assume that \mathbf{u} is used to keep $\mathbf{z} = \mathbf{z}_s$ (with no control error). Solving equation (10) with respect to \mathbf{u} when $\mathbf{z} = \mathbf{z}_s$ gives

$$\mathbf{u} = \mathbf{G}_z^{-1} \mathbf{z}_s - \mathbf{G}_z^{-1} \mathbf{G}_z^d \mathbf{d}$$

By combining equations (8) and the above expression for \mathbf{u} , we have

$$\mathbf{y} = \underbrace{\mathbf{G}_y \mathbf{G}_z^{-1}}_{\mathbf{G}_y^{cl}} \mathbf{z}_s + \left(\underbrace{\mathbf{G}_y^d - \mathbf{G}_y \mathbf{G}_z^{-1} \mathbf{G}_z^d}_{\mathbf{F}'_y} \right) \mathbf{d}$$

Introducing the optimal sensitivity \mathbf{F}'_y and the closed-loop gain \mathbf{G}_y^{cl} we get

$$\mathbf{y} = \mathbf{G}_y^{cl} \mathbf{z}_s + \mathbf{F}'_y \mathbf{d}$$

By combining equations (9), (7) and (5), the following expression for $\hat{\mathbf{y}}$ as an explicit function of \mathbf{y}_s , \mathbf{d} and \mathbf{n}^x is obtained.

$$\hat{\mathbf{y}} = \mathbf{H} \left[\underbrace{\mathbf{G}_x \mathbf{G}_z^{-1}}_{\mathbf{G}_x^{cl}} \mathbf{z}_s + \left(\underbrace{\mathbf{G}_x^d - \mathbf{G}_x \mathbf{G}_z^{-1} \mathbf{G}_z^d}_{\mathbf{F}'_x} \right) \mathbf{d} + \mathbf{n}^x \right]$$

Using the definition of prediction error with the expression for \hat{y} and y gives

$$e(\mathbf{H}) = \begin{bmatrix} (\mathbf{G}_y^{cl} - \mathbf{H}\mathbf{G}_x^{cl}) & (\mathbf{F}'_y - \mathbf{H}\mathbf{F}'_x) & -\mathbf{H} \end{bmatrix} \begin{bmatrix} z_s \\ d \\ \mathbf{n}^x \end{bmatrix}$$

Proceeding analogous to Lemma 2 and Theorem 1, will result in the given proposition. Q.E.D.

Note that Theorem 3 is a generalization of Theorems 1 and 2, since setting $z = u$ gives Theorem 1 and setting $z = y$ gives Theorem 2.

The "closed-loop" estimator (Case S4)

In this section, we derive an expression for the optimal estimator under the assumption that the prediction $\hat{y} = \mathbf{H}\mathbf{x}_m$ is used for controlling the primary variables, that is, we have $\hat{y} = y_s$ (assuming integral action in the controller). It is assumed that $\dim(y) = \dim(u)$.

Theorem 4. *The optimal "closed-loop" estimator \mathbf{H} (denoted \mathbf{H}_{CL}) following the linear relationship*

$$\hat{y} = \mathbf{H}\mathbf{x}_m \tag{17}$$

that minimizes the variance of the prediction error

$$e = y - \hat{y}$$

for normally distributed sets of d, \mathbf{n}^x and y_s (of magnitudes $\mathbf{W}_d, \mathbf{W}_{n^x}$ and \mathbf{W}_{y_s} , respectively) assuming that the degrees of freedom u are adjusted to keep the prediction at the setpoint ($\hat{y} = y_s$), is

$$\mathbf{H}_{CL} = \arg(\min_{\mathbf{H}} \left\| \mathbf{H} \begin{bmatrix} \mathbf{F}\mathbf{W}_d & \mathbf{W}_{n^x} \end{bmatrix} \right\|_F) \tag{18a}$$

$$s.t. \mathbf{H}\mathbf{G}_x = \mathbf{G}_y \tag{18b}$$

where the sensitivity matrix \mathbf{F} is defined as

$$\mathbf{F} = \left(\frac{\partial \mathbf{x}}{\partial \mathbf{d}} \right)_{y=0} = \mathbf{G}_x^d - \mathbf{G}_x \mathbf{G}_y^{-1} \mathbf{G}_y^d \quad (18c)$$

Comment: Note that (18b) is equivalent to $\mathbf{H}\mathbf{G}_x^{cl} = \mathbf{I}$

Proof. An expression for the prediction as an explicit function of \mathbf{u} , \mathbf{d} and \mathbf{n}^x is achieved by combining Equations (9), (7) and (5) to get

$$\hat{\mathbf{y}} = \mathbf{H} \left(\mathbf{G}_x \mathbf{u} + \mathbf{G}_x^d \mathbf{d} + \mathbf{n}^x \right) \quad (19)$$

Using a controller with integral action, the prediction $\hat{\mathbf{y}}$ is held at the setpoints y_s by manipulating \mathbf{u} . Solving equation (19) with respect to \mathbf{u} when $\hat{\mathbf{y}} = y_s$, gives

$$\mathbf{u} = -(\mathbf{H}\mathbf{G}_x)^{-1} \mathbf{H} \left(\mathbf{G}_x^d \mathbf{d} + \mathbf{n}^x \right) + (\mathbf{H}\mathbf{G}_x)^{-1} y_s \quad (20)$$

and inserting this into (8) yields

$$\mathbf{y} = -\mathbf{G}_y (\mathbf{H}\mathbf{G}_x)^{-1} \mathbf{H} [\mathbf{F}\mathbf{d} + \mathbf{n}^x] + \mathbf{G}_y (\mathbf{H}\mathbf{G}_x)^{-1} y_s \quad (21)$$

where $\mathbf{F} = (\mathbf{G}_x^d - \mathbf{G}_x \mathbf{G}_y^{-1} \mathbf{G}_y^d)$ is the optimal sensitivity. Inserting the expression for \mathbf{y} into the prediction error \mathbf{e} , remembering that the prediction is kept at the setpoint ($\hat{\mathbf{y}} = y_s$), gives

$$\mathbf{e} = \mathbf{y} - \hat{\mathbf{y}} = \mathbf{y} - y_s = -\mathbf{G}_y (\mathbf{H}\mathbf{G}_x)^{-1} \mathbf{H} (\mathbf{F}\mathbf{d} + \mathbf{n}^x) + \left[\mathbf{G}_y (\mathbf{H}\mathbf{G}_x)^{-1} - \mathbf{I} \right] y_s \quad (22)$$

Introducing normalized (weighted) variables, gives

$$\mathbf{e} = \underbrace{-\mathbf{G}_y (\mathbf{H}\mathbf{G}_x)^{-1} \mathbf{H} \begin{bmatrix} \mathbf{F}\mathbf{W}_d & \mathbf{W}_{n^x} \end{bmatrix}}_{\mathbf{e}_1(\mathbf{H})} \begin{bmatrix} \mathbf{d}' \\ \mathbf{n}^{x'} \end{bmatrix} + \underbrace{\left[\mathbf{G}_y (\mathbf{H}\mathbf{G}_x)^{-1} - \mathbf{I} \right] y_s}_{\mathbf{e}_2(\mathbf{H})} \quad (23)$$

In the first term of equation (23), we have extra degree of freedom, because if we pre-multiply \mathbf{H} by a matrix \mathbf{D} , we will have

$$e_1(\mathbf{H}) = e_1(\mathbf{DH})$$

where \mathbf{D} is any nonsingular square matrix. This follows because

$$(\mathbf{DHG}_x)^{-1}\mathbf{DH} = (\mathbf{HG}_x)^{-1}\mathbf{D}^{-1}\mathbf{DH} = (\mathbf{HG}_x)^{-1}\mathbf{H}$$

Since \mathbf{D} can be chosen freely without affecting $e_1(\mathbf{H})$, we may choose it such that the last term is zero, $e_2(\mathbf{H}) = 0$, corresponding to having $\mathbf{HG}_x = \mathbf{G}_y$. This means that the optimal \mathbf{H} can be found by minimizing the first term (e_1) in equation (23), subject to the constraint $\mathbf{HG}_x = \mathbf{G}_y$. This problem is equivalent to solving the constrained minimization problem (18) which is convex.¹³ Q.E.D.

Comment: The optimization problem in equation (18) is expressed with open-loop gains (\mathbf{G}_x and \mathbf{G}_y), but can also be expressed with closed-loop gains by just substituting the open-loop gains for the closed-loop gains. This can easily be shown by postmultiplying the constraint $\mathbf{HG}_x = \mathbf{G}_y$ with \mathbf{G}_y^{-1} on both sides of the equality, to get $\mathbf{HG}_x\mathbf{G}_y^{-1} = \mathbf{HG}_x^{cl} = \mathbf{I}$.

Analytical Solution for \mathbf{H}

If $\tilde{\mathbf{F}} \triangleq \begin{bmatrix} \mathbf{FW}_d & \mathbf{W}_{n^x} \end{bmatrix}$ is full rank, which is always the case if we include independent measurement noise (so that \mathbf{W}_{n^x} is full rank), then we may alternatively use the analytic expression in Theorem 5.

Theorem 5. *Under the assumption that $\tilde{\mathbf{F}}\tilde{\mathbf{F}}^T$ is full rank, an analytical solution for the problem (18) is*

$$\mathbf{H}_{CL}^T = (\tilde{\mathbf{F}}\tilde{\mathbf{F}}^T)^{-1} \mathbf{G}_x \left(\mathbf{G}_x^T (\tilde{\mathbf{F}}\tilde{\mathbf{F}}^T)^{-1} \mathbf{G}_x \right)^{-1} \mathbf{G}_y \quad (24)$$

Proof. The proof is in the paper written by Alstad et al.¹³ and is based on first vectorizing the problem and then using standard results from constrained quadratic optimization. Q.E.D.

Remark 1. One special case, when the expression for \mathbf{H} in equation (24) applies also for $\mathbf{W}_{n^x} = 0$, is when there are more independent than measurements, because $\tilde{\mathbf{F}}\tilde{\mathbf{F}}^T$ then remains full rank.¹³

Remark 2. The solution (24) is equivalent to the following¹⁴

$$\mathbf{H}_{CL} = \mathbf{D} \left((\tilde{\mathbf{F}}\tilde{\mathbf{F}}^T)^{-1} \mathbf{G}_x \right)^T \quad (25)$$

where

$$\mathbf{D} = \mathbf{G}_y \left(\mathbf{G}_x^T (\tilde{\mathbf{F}}\tilde{\mathbf{F}}^T)^{-1} \mathbf{G}_x \right)^{-1} \quad (26)$$

The following example shows the effect of noise for various cases.

Example 1

We consider a scalar case with one input (u), one disturbance (d), one measurement (x), one output y, and with the following model matrices

$$\mathbf{G}_x = \mathbf{G}_x^d = 1$$

$$\mathbf{G}_y = \mathbf{G}_y^d = 1$$

$$\mathbf{W}_u = \mathbf{W}_d = \mathbf{W}_{y_s} = 1$$

This corresponds to the case where $y = x$ and we have $\mathbf{F} = 0$.

For case S1, Theorem 1 gives

$$\mathbf{Y}_1 = \begin{bmatrix} 1 & 1 & 0 \end{bmatrix}$$

$$\mathbf{X}_1 = \begin{bmatrix} 1 & 1 & \mathbf{W}_{n^x} \end{bmatrix}$$

and we find

$$\mathbf{H}_1 = \frac{2}{\mathbf{W}_{n^x}^2 + 2}$$

For case S2, Theorem 2 gives

$$\mathbf{Y}_2 = \begin{bmatrix} 1 & 0 & 0 \end{bmatrix}$$

$$\mathbf{X}_2 = \begin{bmatrix} 1 & 0 & \mathbf{W}_{n^x} \end{bmatrix}$$

and we find

$$\mathbf{H}_2 = \frac{1}{\mathbf{W}_{n^x}^2 + 1}$$

For case S4, Equation 24 gives

$$\tilde{\mathbf{F}}\tilde{\mathbf{F}}^T = (\mathbf{W}_{n^x})^2$$

and we have $\mathbf{H}_{CL} = 1$ for all values of the measurement noise \mathbf{W}_{n^x} .

Table 1 shows the optimal \mathbf{H} for the three cases for some values of the measurement noise. For the "monitoring" cases (\mathbf{H}_1 and \mathbf{H}_2), the optimal estimator gain \mathbf{H} approaches zero when the measurement noise goes to infinity, but this does not occur for the closed-loop estimator (\mathbf{H}_{CL}). The reason is that the estimate $\hat{y} = \mathbf{H}_{CL}x_m$ is used for control, that is, u is changed such that \hat{y} is equal to y_s . If we used an estimator where $\mathbf{H}_{CL} \rightarrow 0$ then we would need u to go to infinity, which is not optimal.

Table 1: Optimal \mathbf{H} matrix for different values of the measurement noise in Example 1

| \mathbf{W}_{n^x} | \mathbf{H}_1 | \mathbf{H}_2 | \mathbf{H}_{CL} |
|--------------------|----------------|----------------|-------------------|
| 0 | 1 | 1 | 1 |
| 1 | 0.67 | 0.5 | 1 |
| 5 | 0.074 | 0.038 | 1 |
| ∞ | 0 | 0 | 1 |

Data-based Estimators

So far we have assumed that we have available a model, which are given by \mathbf{G}_x , \mathbf{G}_x^d , \mathbf{G}_y and \mathbf{G}_y^d in equations 8 and 9, and the expected magnitudes of disturbances and measurement noise, etc.

were given by weighting matrices (e.g. \mathbf{W}_d and \mathbf{W}_n^x). Here, we consider the data-based case where we start from the observations collected in the matrices \mathbf{X} and \mathbf{Y} . We want to obtain a linear relationship between the data sets.

$$\mathbf{Y} = \mathbf{X}\mathbf{B} + \mathbf{B}_0 \quad (27)$$

where \mathbf{B} and \mathbf{B}_0 as optimization variables. \mathbf{B}_0 is normally zero if the data are centered.

Least Squares Solution

The least-square solution to this problem is

$$\mathbf{B} = \mathbf{Y}\mathbf{X}^\dagger \quad (28)$$

It can be seen to be a direct generalization of the "monitoring" estimators in Theorems 1,2 and 3.

Principal Component Regression (PCR) Method

A variant of Least Square is PCR. It starts with a principal component singular value analysis of the data matrix \mathbf{X} , to remove directions in \mathbf{X} data with little information. The matrix is truncated to rank a , where a is the number of principal components, and gives $\tilde{\mathbf{X}} = \tilde{\mathbf{U}}_a \tilde{\Sigma}_a \tilde{\mathbf{V}}_a^T$. The optimal estimator is then

$$\mathbf{B}_{PCR} = \mathbf{Y}\tilde{\mathbf{X}}^\dagger$$

where $\tilde{\mathbf{X}}^\dagger$ is the inverse of the truncated SVD of the matrix \mathbf{X} .

Partial Least Square (PLS) Method

In its general form PLS creates orthogonal score vectors (called latent vectors or components) by maximizing the covariance between different sets of variables. There are several different algorithms generating bases which all give the same predictor, when there is one \mathbf{Y} variable. Rosipal et al. present a review of the different forms.¹⁵ The first approach was nonlinear iterative par-

tial least squares (NIPALS) by Wold et al.¹⁶ The predictor data matrix $\mathbf{X} = [x_1, x_2, \dots, x_r]$, containing the values of r predictors for N samples is compressed into a set of A latent variable or factor scores $\mathbf{T} = [t_1, t_2, \dots, t_A]$, where $a \leq r$. These factors are determined sequentially using NIPALS. The orthogonal factor scores are used to fit a set of N observations to m dependent variables $\mathbf{Y} = [y_1, y_2, \dots, y_m]$.

There are some assumptions which are inherent in the problem definition or some in the solution procedure, which are as follows:¹⁷

1. Assume centered data generated according to the latent variable model
2. Weight matrix should have orthonormal column vectors
3. The number of y variables is less than the number of components ($m \leq A$)
4. Components of measurement variables and response variables are independent, i.e. diagonal expectations $E(x_k, x_k^T) = 0$ and $E(y_k, y_k^T) = 0$
5. The most important assumption is that the outputs and the input data have linear relationship.

The NIPALS method includes various iterative orthogonalization (deflation) processes. Di Ruscio et al. has presented a new interpretation and description of the basic PLS solution which is non-iterative, which is more interesting for control community.¹⁸ This solution can be expressed in terms of some weighting vectors only. The equivalence between this method and the NIPALS version of the PLS method is demonstrated by Elden et al. by proving that they give the same sequence of orthogonal basis vectors.¹⁹ The weight matrix \mathbf{W}_a is of size $r \times a$ (so the number of components, a , should of course first be specified). They have first calculated the weight vectors by an orthogonalization process. The solution is parameterized as $\mathbf{B} = \mathbf{W}_a \mathbf{p}$, where the vector \mathbf{p} is chosen to minimize the Frobenius norm of $\mathbf{Y} - \mathbf{X} \times \mathbf{B} = \mathbf{Y} - \mathbf{X} \times \mathbf{W}_a \times \mathbf{p}$ for some specified weighting matrix \mathbf{W}_a .

The orthogonalization process for calculating the weight vectors is not unique. It is evident that any weighting matrix defined as $\mathbf{W}_a := \mathbf{W}_a \mathbf{D}$ (where $\mathbf{D} \in \mathbb{R}^{a \times a}$ is defined as a non-singular

transformation matrix) can be a solution for this problem, as mentioned by Di Ruscio et al.¹⁸ So, by taking the weights \mathbf{W}_a from the Krylov subspace or from the space which span the Krylov subspace, the optimal weights will be found in the sense that an iterative Ordinary Least square (OLS) converges the fastest to the OLS solution, i.e. in a minimum number of iterations.¹⁸

New data-based estimation

We want to use our results for the optimal model-based estimators, to derive data-based estimators. The first step is to obtain the required model to use for cases S1-S4 in Theorems 1-4.

Monitoring cases

For cases S1-S3, all the optimal estimators are on the form $\mathbf{H} = \mathbf{YX}^\dagger$, so we may use the data directly. The result will be identical to the conventional least squares solution, which from our derivation should be the optimal estimator for the case when there is no measurement noise for y .

Closed-loop estimator

Let us now consider the more interesting case S4, where we want to find the optimal estimator to be used for closed-loop operation. To use Theorem 4, we need to have information about $\tilde{\mathbf{F}} = \begin{bmatrix} \mathbf{F}\mathbf{W}_d & \mathbf{W}_{n^x} \end{bmatrix}$ and $\mathbf{G}_x\mathbf{G}_y^{-1} = \mathbf{G}_x^{cl}$.

This information can be obtained by transforming the original data in \mathbf{Y} and \mathbf{X} , to match the "closed-loop" form as given by the matrices \mathbf{Y}_2 and \mathbf{X}_2 in (16):

$$\mathbf{Y}_2 = \begin{bmatrix} \mathbf{W}_{y_s} & 0 \end{bmatrix}$$

$$\mathbf{X}_2 = \begin{bmatrix} \mathbf{G}_x^{cl}\mathbf{W}_{y_s} & \tilde{\mathbf{F}} \end{bmatrix}$$

This may be done as follows. Collect all the experimental data in the big matrix \mathbf{Y}_{all} .

$$\mathbf{Y}_{all} = \begin{bmatrix} \mathbf{Y} \\ \mathbf{X} \end{bmatrix} \quad (29)$$

Then

1. Perform a singular value decomposition on the data matrix $\mathbf{Y} = \mathbf{U}\mathbf{\Sigma}\mathbf{V}^T$
2. Multiply the data matrix \mathbf{Y}_{all} with the unitary matrix \mathbf{V} to get $\mathbf{Y}_{all}\mathbf{V}$ on the desired form

$$\mathbf{Y}_{all}\mathbf{V} = \begin{bmatrix} \mathbf{W}_{y_s} & 0 \\ \mathbf{G}_x^{cl}\mathbf{W}_{y_s} & \tilde{\mathbf{F}} \end{bmatrix} \quad (30)$$

where $\tilde{\mathbf{F}} = \begin{bmatrix} \mathbf{F}\mathbf{W}_d & \mathbf{W}_{n^x} \end{bmatrix}$. $\tilde{\mathbf{F}}$ is denoted \mathbf{X}_{opt} in the following.

Note that \mathbf{F} is defined as $\left(\frac{\partial x}{\partial d}\right)_{y=0}$. Since \mathbf{V} is a unitary matrix, the magnitude of the prediction error does not change when it is multiplied by \mathbf{V} , so $\|\mathbf{Y}\mathbf{V} - \mathbf{H}\mathbf{X}\mathbf{V}\|_F = \|\mathbf{Y} - \mathbf{H}\mathbf{X}\|_F$. This follows because the singular vectors satisfy $\mathbf{V}^T = \mathbf{V}^{-1}$, so we have

$$\mathbf{Y}\mathbf{V} = \mathbf{U}\mathbf{\Sigma} = \begin{bmatrix} \mathbf{U}_1 & \mathbf{U}_2 \end{bmatrix} \begin{bmatrix} \mathbf{\Sigma}_1 \\ 0 \end{bmatrix} = \begin{bmatrix} \mathbf{U}_1\mathbf{\Sigma}_1 & 0 \end{bmatrix}$$

\mathbf{G}_x^{cl} can be easily calculated. To find \mathbf{G}_x and \mathbf{G}_y , which are needed to calculate the optimal \mathbf{H} matrix (denoted by \mathbf{B}_{CL} in the following), we assume that the degrees of freedom are chosen to be the primary variables. This will result in $\mathbf{G}_y = \mathbf{I}$.

The closed-loop data-based estimator (\mathbf{B}_{CL}) suffers from the same weakness as ordinary least-squares, giving poor results for ill-conditioned matrices and underdetermined systems. Performing a principal component analysis on the \mathbf{X} data will remove the weaker directions containing noise resulting in a well-conditioned matrix. Then, closed-loop data-based estimator can be applied to the data. We call this ‘‘truncated closed-loop estimator’’ (\mathbf{B}_{CL}^\dagger).

Examples

Example 2

To investigate the performance of the estimators, they were applied to a linear approximation of a binary distillation column model - Column A²⁰ - subjected to different control cases. Full information about the model and the source codes are online. There are two inputs, namely the reflux flow and the boilup, and one disturbance, which is the change in feed composition. The linearized model for open-loop system for the two primary variables is

$$y = \begin{bmatrix} 0.8754 & -0.8618 \\ 1.0846 & -1.0982 \end{bmatrix} u + \begin{bmatrix} 0.8812 \\ 1.1188 \end{bmatrix} d \quad (31)$$

where the primary variables are compositions of the two main components in the top and bottom products. The model for the eight measurements (temperatures) is

$$x_m = \begin{bmatrix} -64.665 & 65.413 \\ -171.884 & 173.569 \\ -226.276 & 227.842 \\ -130.878 & 130.911 \\ -195.132 & 193.623 \\ -142.092 & 140.419 \\ -55.816 & 55.013 \\ -11.818 & 11.634 \end{bmatrix} u + \begin{bmatrix} -67.174 \\ -180.728 \\ -242.622 \\ -146.618 \\ -207.430 \\ -146.928 \\ -56.667 \\ -11.897 \end{bmatrix} d + n^x \quad (32)$$

These measurements are chosen from the top and bottom sections in the column. The two secondary variables, which are reflux flow and a temperature measurement from 25th tray of column, are given by

$$z = \begin{bmatrix} 1 & 0 \\ -195.132 & 193.623 \end{bmatrix} u + \begin{bmatrix} 0 \\ -207.4297 \end{bmatrix} d \quad (33)$$

This means that the reflux flow rate and the temperature measurement from 25th tray are controlled and their setpoints are the degrees of freedom. The disturbance and noise variances are as below for all cases:

$$\mathbf{d} \sim \mathcal{N}(\mathbf{0}, 0.05^2 \mathbf{I}_2)$$

$$\mathbf{n}^x \sim \mathcal{N}(\mathbf{0}, 0.5^2 \mathbf{I}_8)$$

Since there is no control in the first case, the standard deviation in u ($\sigma \approx 0.05$) was selected to give a small standard deviation in y . The resulting standard deviations in the primary variables for all cases are the same.

Table 2: Four operation cases

| Operation | Estimator | Input variables | Variable distribution |
|-----------------|-------------------|---|--|
| Open-loop | \mathbf{H}_1 | u | $u \sim \mathcal{N}(0, 0.08^2 \mathbf{I}_2)$ |
| $y = y_s$ | \mathbf{H}_2 | $\mathbf{G}_y^{-1}(y_s - \mathbf{G}_y^d \mathbf{d})$ | $y_s \sim \mathcal{N}(0, 0.005^2 \mathbf{I}_2)$ |
| $z = z_s$ | \mathbf{H}_3 | $\mathbf{G}_z^{-1}(z_s - \mathbf{G}_z^d \mathbf{d})$ | $z_s \sim \mathcal{N}(0, [0.05^2 \quad 2^2] \mathbf{I}_2)$ |
| $\hat{y} = y_s$ | \mathbf{H}_{CL} | $(\mathbf{H}\mathbf{G}_x)^{-1}[\mathbf{H}(\mathbf{G}_x^d \mathbf{d} + \mathbf{n}^x) + y_s]$ | $y_s \sim \mathcal{N}(0, 0.005^2 \mathbf{I}_2)$ |

For the data-based estimators, calibration data was generated by drawing 32 random values for u , \mathbf{d} , y_s and z_s with the distributions given in Table 2, and calculating the corresponding output variables x_m and y for the respective cases (except case 4). This gave one set of calibration data with 32 experiments: \mathbf{X} (8×32) and \mathbf{Y} (2×32). The median of the prediction error for 150 runs are used to assess the estimators' performances because noise and variation in input variables resulted in a distorted picture of estimator performance by outliers.

Model-based estimators

Table 3 shows the results of validation for model-based for different cases. For each case (S1, S2, S3 and S4), the matrix \mathbf{H} is obtained first, using theorems 1-4. For example for case S4 we obtain

$$\mathbf{H}_{CL} = \begin{bmatrix} -0.0024 & 0.0008 \\ 0.0004 & -0.0041 \\ -0.0001 & -0.0017 \\ -0.0025 & -0.0001 \\ 0.0011 & 0.0004 \\ 0.0003 & 0.0013 \\ 0.0007 & -0.0026 \\ -0.0037 & 0.0005 \end{bmatrix}$$

Then, they were validated on the data generated randomly for each case (S1, S2, S3, S4), with the given standard deviations for n^x , u , z_s , y_s (see Table 2). The validation is done by first calculating u for the given case and then substituting into the model. The reported data in Table 3 shows the median of the prediction errors. In Table 3, the diagonal elements correspond to the optimal estimators for the intended cases, and, as expected, the prediction error is smallest along the diagonal. Note that the cases are not comparable along the rows because of different variances for different cases. Calibrating with one case and validating with another is mostly applicable to the last case. So, the shaded cells are actually showing the more interesting data.

Table 3: The mean prediction error of the model-based estimators applied to four operation cases

| Estimator | Cases | | | |
|-----------|--------|--------|--------|--------|
| | S1 | S2 | S3 | S4 |
| S1 | 0.0168 | 0.0248 | 0.0177 | 0.1972 |
| S2 | 0.271 | 0.0156 | 0.035 | 0.0221 |
| S3 | 0.0207 | 0.0224 | 0.0176 | 0.1021 |
| S4= CL | 0.0187 | 0.0187 | 0.0187 | 0.0187 |

The prediction errors are equal for all the cases for S4 due to the constraint $\mathbf{G}_y = \mathbf{H}\mathbf{G}_x$. The

closed-loop estimator generally gives the best performance.


Data-based estimators

Table 4 shows the results of validation for data-based estimators. As mentioned in the previous section, the dashed cells are the more interesting data.


Table 4: The mean prediction error of the data-based estimators applied to four operation scenarios

| | | Loss | | | | |
|------------------|-----------------------------|----------------------|-------|-------|-------|-------|
| Operation | Estimator | S1 | S2 | S3 | S4 | |
| Calibration Data | S1 | $\mathbf{B}_{LS,1}$ | 0.017 | 0.019 | 0.018 | 0.02 |
| | S2 | $\mathbf{B}_{LS,2}$ | 0.316 | 0.016 | 0.061 | 0.173 |
| | S3 | $\mathbf{B}_{LS,3}$ | 0.077 | 0.022 | 0.017 | 0.054 |
| | S1 | $\mathbf{B}_{PCR,1}$ | 0.017 | 0.018 | 0.017 | 0.018 |
| | S2 | $\mathbf{B}_{PCR,2}$ | 0.379 | 0.015 | 0.069 | 0.192 |
| | S3 | $\mathbf{B}_{PCR,3}$ | 0.091 | 0.023 | 0.016 | 0.065 |
| | S1 | $\mathbf{B}_{PLS,1}$ | 0.016 | 0.018 | 0.017 | 0.018 |
| | S2 | $\mathbf{B}_{PLS,2}$ | 0.352 | 0.014 | 0.067 | 0.192 |
| | S3 | $\mathbf{B}_{PLS,3}$ | 0.077 | 0.021 | 0.016 | 0.055 |
| | S1 | $\mathbf{B}_{CL,1}$ | 0.018 | 0.02 | 0.018 | 0.020 |
| | S2 | $\mathbf{B}_{CL,2}$ | 0.132 | 0.018 | 0.028 | 0.067 |
| | S3 | $\mathbf{B}_{CL,3}$ | 0.077 | 0.022 | 0.017 | 0.053 |
| S1 | $\mathbf{B}_{CL,1}^\dagger$ | 0.017 | 0.019 | 0.017 | 0.019 | |
| S2 | $\mathbf{B}_{CL,2}^\dagger$ | 0.130 | 0.016 | 0.028 | 0.066 | |
| S3 | $\mathbf{B}_{CL,3}^\dagger$ | 0.088 | 0.024 | 0.016 | 0.061 | |

Figure 4 shows the "closed-loop" performance with two different data sets. The number of measurements is increased from 8 to 41 (the total number of stages). All estimators are trained on calibration data from case 2 and validated on case 4. The performance of new closed-loop estimator (shown with \mathbf{B}_{CL} in Figure 4) and the ordinary least square estimator (shown with \mathbf{B}_{LS} in Figure 4) was deteriorated when then the system was over-determined with low number of data. This is because they were forced to use the weak directions and assimilate noise and collinearity. Since the truncated closed-loop estimator (\mathbf{B}_{CL}^\dagger in Figure 4) filters out the noise, it results in better performance. Comparing the two figures in Figure 4, we will see that if the data-based estimators are given enough data they will approach their model-based counterparts.



(a) Median prediction error for 150 data set with 32 samples



(b) Median prediction error for 150 data set with 200 samples

Figure 4: Median prediction error for two sample sizes (validated for S4)

Example 3

The next example is from a multi-component distillation column (4 components) which is simulated rigorously. The schematic of the distillation process with estimator is shown in Figure 5.




Figure 5: Schematic of the distillation process with estimator

The two lightest and the two heaviest products are supposed to be separated in the column. The feed stream is a saturated liquid mixture of methanol, ethanol, 1-propanol, 1-butanol. Disturbances are composition, flow rate, quality, Pressure in the feed stream and also condenser pressure. The composition setpoints for 1-propanol in the top ($x_{C_3 in D}$) and ethanol in the bottom ($x_{C_2 in B}$) of prefractionator are 0.0095 and 0.038 respectively.

Here we show how simple the closed-loop model-based estimator can be derived by choosing the right variables as manipulated variable. We can actually consider u to be any two variables from the process. For the sake of simplicity and because we can use the close-loop information of the system, we select the inputs to the estimation model to be equal to the product compositions, in our case

$$\mathbf{u} = \mathbf{y} = \begin{bmatrix} x_{C_3 in D} & x_{C_2 in B} \end{bmatrix}$$

This will make the case easier and the matrices will be as below:

$$\mathbf{G}_y = \mathbf{I}$$

$$\mathbf{G}_x^d = \mathbf{F}$$


$$\mathbf{G}_y^d = 0$$

We use exactly the same information for PLS method. \mathbf{X} and \mathbf{Y} in PLS method are the first and second row of \mathbf{Y}_{all} matrix (Equation (29)) respectively. We have assumed that we have temperature sensors in every 4th tray. The matrices in the following show the fitting matrices for the two methods (\mathbf{B} for PLS and \mathbf{H}_{CL} is from equation 24).


$$\mathbf{B} = \begin{bmatrix} -0.0045 & 0.0075 \\ 0.0113 & -0.0076 \\ -0.0036 & 0.0037 \\ -0.0038 & -0.0013 \\ 0.0074 & -0.0092 \\ -0.0055 & 0.0152 \\ -0.0022 & 0.0057 \\ 0.0011 & -0.0140 \end{bmatrix}$$

$$\mathbf{H}_{CL} = \begin{bmatrix} -0.0038 & 0.0080 \\ 0.0104 & -0.0082 \\ -0.0028 & 0.0041 \\ -0.0035 & -0.0011 \\ 0.0059 & -0.0101 \\ -0.0049 & 0.0156 \\ -0.0019 & 0.0059 \\ 0.0010 & -0.0141 \end{bmatrix}$$

Figure 6 shows the dynamic behaviour of the model as disturbances happen and also of the estimators. It is shown that the estimated values can track the real composition very well. It should be noted that the steady state value is more in focus since the methods under study are static estimators. The dynamic behaviour can be corrected by feedback.



(a) +10% disturbance in feed flow



(b) -4% disturbance in Feed composition $z_{1,F}$

Figure 6: Estimated and model Composition values for the case with two temperature controls and with the consideration of 8 measurements

Further Examples

Some additional examples are provided by Skogestad et al.,¹⁴ where the new closed-loop estimator is compared with PCR and PLS. It is also suggested that adding "artificial noise" may provide additional degrees of freedom for our method. This is particularly relevant when there are a large number of measurement (x), but relatively few samples, for example, for spectroscopic data, because it is then difficult to obtain a good estimate of \mathbf{W}_n^x using equation (30). The idea is to add an extra diagonal matrix \mathbf{W}'_{n^x} to the end of $\mathbf{X}_{opt} = \tilde{\mathbf{F}}$, which contains the expected noise for each measurement x along its diagonal.

Discussion

Relationship to self-optimizing control

This work originated from considering the "indirect control problem"¹⁰ using the "exact local method" in self-optimizing control. In "indirect control" the objective is to find a set of controlled variables $c = \mathbf{H}x$ such that by keeping c constant, we indirectly keep the primary variables y constant (or more specifically, at their desired setpoints y_s), in spite of disturbances d and measurement noise n^x . This can be viewed as a special case of "self-optimizing control" with cost function $J = \|y - \hat{y}\|_2$. We can then apply the theory that has been developed for "self-optimizing" control, which includes the "exact local method". This directly leads to the result in Theorem 4, when the "extra degrees of freedom" in \mathbf{H} are selected such that $c = \hat{y}$. This requires some explanation. In indirect control, we adjust the inputs u by feedback to keep $c = \mathbf{H}x = 0$ (constant). Note that we will generate the same inputs u (for a given d and n^x), also if we keep $c' = \mathbf{D}c = 0$ where \mathbf{D} is any invertible matrix. The matrix \mathbf{D} is the so-called "extra degrees of freedom" in \mathbf{H} .

It is clear that one good variable $c = \mathbf{H}x$ to use for indirect control of y is the estimate \hat{y} . However, if we look the other way around, then the optimal c will not necessarily correspond to an estimate of y (\hat{y}). However, there are extra degrees of freedom in selecting $c = \mathbf{H}x$, we can use these extra degrees of freedom (i.e., the \mathbf{D} -matrix), to make $c = \mathbf{H}x$ equal to \hat{y} , which is in fact done when we select \mathbf{H} such that $\mathbf{H}\mathbf{G}_x = \mathbf{G}_y$ (see Theorem 4).

Comparison with work of Pannocchia and Brambilla

Our paper provides an extension of the results of Pannocchia and Brambilla¹¹ on "steady-state closed-loop consistency" to include also measurement noise. In addition, we have shown, in agreement with the results in the paper by Hori et al.,¹⁰ that we can always achieve "perfect consistency" for setpoint changes, that is, the use of the "extra degrees of freedom" in \mathbf{H} , makes it possible to always have the norm from y_s to the prediction error ($y - \hat{y}$) equal to zero, without sacrificing the norm from disturbances (d) to the prediction error. In the notation of Pannocchia and Brambilla¹¹

this means that we can always make $\varepsilon_r = 0$ without sacrificing the norm of ε_d .

The inclusion of measurement noise is important, because this is often a critical factor. As an example, consider the estimation of the two product compositions in a distillation column ($y = \begin{bmatrix} x_D & x_B \end{bmatrix}$) based on temperature measurements ($x = T$). For a binary distillation column with constant pressure, temperature and compositions are uniquely related. So, if there were no measurement noise ($n^x = 0$), one could in theory have a perfect estimate of y by measuring the temperature at the two columns ends ($x = \begin{bmatrix} T_D & T_B \end{bmatrix}$), irrespective of any disturbances in feed composition or feed rate (which may affect stage efficiency). However, in practice, the estimate will be poor because of measurement error, especially for high-purity columns. For example, assume the bottom product of a methanol/water distillation column should be about 99.99% water. At 1 atm, the boiling point of this mixture will be approximately $(0.9999 \times 100^\circ\text{C} + 0.0001 \times 65^\circ\text{C}) = 99.9965^\circ\text{C}$, whereas the boiling point of 100% water is 100.00°C . Thus, if we have a measurement error of more than 0.0035°C (which we certainly will have), then the temperature measurement will be useless to infer composition as it would lead to predicting negative compositions. Thus, due to measurement error (n^x), we need to locate the temperature sensor away from the column end, and the optimal location can be found using the methods presented in this paper which include measurement noise.

Measurement selection

The results presented in this paper also provide the basis for optimal measurement selection, which extends Algorithm 1 in Pannocchia and Brambilla¹¹ to include measurement noise. For example, assume there are 10 candidate measurements, and there are 2 outputs that we want to estimate (i.e., we have 2 y 's and 2 u 's). Assume that we want to use 4 out of these 10 measurements. There are then 210 candidate measurement sets, and we find the best set by computing for each set the prediction error using Theorem 4. To avoid checking all sets, we can also use the branch and bound method developed by Kariwala and Cao.²¹

Comparison to standard data-based estimators

1. In least squares regression (LS), one gets $\mathbf{B} = \mathbf{Y}\mathbf{X}^{-1}$, or more generally $\mathbf{B} = \mathbf{Y}\mathbf{X}^\dagger$, where \mathbf{X}^\dagger denotes the pseudo inverse of \mathbf{X} . In principal component regression (PCR), one uses $\mathbf{B} = \mathbf{Y}\mathbf{X}_a^\dagger$ where $\mathbf{X}_a^\dagger = \sum_{i=1}^a \frac{1}{\sigma_i} \mathbf{v}_i \mathbf{u}_i^H$ denotes the pseudo inverse of $\mathbf{X} = \mathbf{U}\Sigma\mathbf{V}^H$ with only a principal components included. Thus, in both LS and PCR one inverts the \mathbf{X} -matrix, while with the new estimation method, see equation (25) in Theorem 3, one considers only a part $\mathbf{X}_{opt} = \tilde{\mathbf{F}}$ of the transformed \mathbf{X} -matrix. It is optimal because the corresponding \mathbf{Y} data are zero. The proposed method seems a bit similar to PLS in that we use the data for \mathbf{Y} to affect the \mathbf{X} -data (we get \mathbf{X}_{opt} from \mathbf{X} by using the SVD of \mathbf{Y}).

2. Comparing the regression equations of our new estimator and PLS, we realize that the PLS method has one more degree of freedom (\mathbf{B}_0), which provides an optimal centering of the data. We may include this degree of freedom into our method as follows: By assuming deviation variables, we may write

$$\mathbf{Y} - \mathbf{Y}_0 = \mathbf{H}(\mathbf{X} - \mathbf{X}_0) \quad (34)$$

or

$$\mathbf{Y} = \mathbf{H}\mathbf{X} + \mathbf{H}_0 \quad (35)$$

where $\mathbf{H}_0 = \mathbf{Y}_0 - \mathbf{H}\mathbf{X}_0$. By writing

$$\mathbf{H}_0 = \mathit{diag}(\mathbf{H}_0) \times \mathbf{1} - \mathit{vector} \quad (36)$$

Equation (35) then can be written as

$$\mathbf{Y}' = \mathbf{H}'\mathbf{X}' \quad (37)$$

where $\mathbf{H}' = \begin{bmatrix} \mathbf{H} & \mathit{diag}(\mathbf{H}_0) \end{bmatrix}$ and $\mathbf{X}' = \begin{bmatrix} \mathbf{X} & \mathbf{1} - \mathit{vector} \end{bmatrix}$.

Thus, by just adding 1's to the end of the \mathbf{X} -data, one can optimize to find \mathbf{H}' , and then find \mathbf{H} and \mathbf{H}_0 .

3. The general equation for \mathbf{B} in PLS is²²

$$\mathbf{B}_{PLS} = \mathbf{W}_a (\mathbf{W}_a^T \mathbf{X}^T \mathbf{X} \mathbf{W}_a)^{-1} \mathbf{W}_a^T \mathbf{w}_1 \quad (38)$$

Comparing this with \mathbf{H} for our closed-loop estimator in equation (25), we see that $\mathbf{X}_{opt} = \tilde{\mathbf{F}}$ is a variation of $\mathbf{W}_a \mathbf{X}$. \mathbf{X}_{opt} is actually \mathbf{XV} in our method, where \mathbf{V} is the right singular vector. It acts as some sort of \mathbf{W}_a .

We must assume that $\mathbf{X}_{opt} = \tilde{\mathbf{F}}$ is full rank (invertible) to use the analytic expression in equation (25). If $\tilde{\mathbf{F}}$ does not have full rank one may use some pseudo-inverse of $\tilde{\mathbf{F}}$ (similar to PCR). This adds degrees of freedom to the method, which in PLS is the size of the matrix \mathbf{W}_a and is specified in the first step (the number of components in PLS). The problem of invertibility is solved by manipulating \mathbf{W}_a matrix.

4. The PLS method for univariate data is optimal in the prediction error sense.¹⁸ However, the PLS algorithm for multivariate data is not optimal in the same way as the PLS algorithm for univariate data. There are reports that from the literature that the PLS solution using different approaches are not equivalent. For example de Jong's SIMPLS²³ is not equivalent to Herman Wold's NIPALS.

5. As mentioned before, the reports from different studies showed that PLS always give a higher coefficient of determination (denoted R^2 in statistics) than PCR (Table 1 in the paper by Wentzell et al.⁷). However, some authors²⁴⁻²⁶ have taken a closer look on the shrinkage properties of PLS and have shown that PLS nearly always can be improved in principle, so the regression method as such is not optimal.

Conclusion

In this paper, we have introduced a new class of static estimators based on minimizing the prediction error. We have considered four different cases, where the first three (S1-S3) correspond to cases where the estimator is used for monitoring, and the fourth case (S4) is when the estimator is

used in closed-loop. The new estimators (Theorems 1-5) are derived based on the assumption that we have available a linear process model. If only we have data available, then these may directly be used for the three monitoring estimators (S1-S3). For the closed-loop estimator (S4), we have proposed a method to extract the data, see equations (29) and (30). For the data-based case, the new estimators have been compared with the established PCR and PLS estimators, and the results were found to be comparable (see Figure 4). For a specific case, our new estimators should be better as they are optimal in terms of minimizing the prediction error, but PCR and PLS are found to generally give good predictions.

Acknowledgement

David Di Ruscio and Inge Svein Helland are acknowledged for discussions about PLS, and Ivar J. Halvorsen is acknowledged for discussions.

References

- (1) Mejdell, T.; Skogestad, S. Estimation of distillation compositions from multiple temperature measurements using partial-least-squares regression. *Ind. Eng. Chem. Res.* **1991a**, *30*, 2543–2555.
- (2) Zhang, J. Inferential feedback control of distillation composition based on PCR and PLS models. 2001.
- (3) Bhartiya, S.; Whiteley, R., J Development of inferential measurements using neural networks. *ISA Transactions* **2001**, *40*, 307–323.
- (4) Yan, W., W; Shao, H., H; Wang, F., X Soft sensing modeling based on support vector machine and Bayesian model selection. *Comput. Chem. Eng.* **2004**, *28*, 1489–1498.
- (5) Massy, W. F. Principal Component Regression in Exploratory Statistical Research. *J. Amer. Statist. Assoc.* **1965**, *60*, 234–246.

- (6) Wold, H. *Path Models with Latent Variables: The NIPALS Approach*; Quantitative Sociology: International Perspectives on Mathematical and Statistical Model Building; Academic Press, 1975.
- (7) Wentzell, P. D.; Montoto, V. Comparison of principal components regression and partial least squares regression through generic simulations of complex mixtures. *Chemom. Intell. Labor. Systems* **2003**, *65*, 257–279.
- (8) Joseph, B.; Brosilow, C. B. Inferential Control of Processes: Part I. Steady State Analysis and Design. *AIChE J.* **1978**, *24*, 485–492.
- (9) Kresta, J. V.; Marlin, T. E.; MacGregor, J. F. Development of Inferential Process Models using PLS. *Computers Chem. Eng* **1994**, *18*, 597–611.
- (10) Hori, E. S.; Skogestad, S.; V., A. Perfect Steady-State Indirect Control. *Ind. Eng. Chem. Res.* **2005**, *44*, 863–867.
- (11) Pannocchia, G.; Brambilla, A. How auxiliary variables and plant data collection affect closed-loop performance of inferential control. *J. Process Control* **2007**, *17*, 653–663.
- (12) Tronci, S.; Bezzo, F.; Barolo, M.; Baratti, R. Geometric observer for a distillation column: development and experimental testing. *Ind. Eng. Chem. Res.* **2005**, *44*, 9884–9893.
- (13) Alstad, V.; Skogestad, S.; Hori, E. S. Optimal measurement combinations as controlled variables. *J. Proc. Control* **2009**, *19*, 138–148.
- (14) Skogestad, S.; Yelchuru, R.; Jäschke, J. Optimal use of measurements for control, optimization and estimation using loss method: Summary of existing results and some new. In: *Selected Topics on Constrained and Nonlinear Control Workbook* (ISBN 978-80-968627-3-3), Editor: M. Huba et al., STU Bratislava and NTNU Trondheim. **2011**, 53–86.
- (15) Rosipal, R.; Krämer, R. Overview and recent advances in partial least squares. In: *'Subspace*,

- Latent Structure and Feature Selection Techniques*, *Lecture Notes in Computer Science* **2006**, 34–51.
- (16) Wold, H. *Soft Modelling by Latent Variables; the Nonlinear Iterative Partial Least Squares Approach*; Academic Press, London, 1975.
- (17) Ergon, R. Noise Handling Capabilities of Multivariate Calibration Methods. *Modeling, identification and control* **2002**, *23*, 259–273.
- (18) Di Ruscio, D. A weighted view on the partial least-squares algorithm. *Automatica* **2000**, *36*, 831–850.
- (19) Elden, L. Partial Least-squares vs. Lanczos Bidiagonalization - I: Analysis of a Projection Method for Multiple Regression. *Comput. Stat. Data Anal.* **2004**, *46*, 11–31.
- (20) Skogestad, S. Dynamics and Control of Distillation Columns: A Critical Survey. *J. Modeling, Identification and Control* **1997**, *18*, 177–217.
- (21) Kariwala, V.; Cao, Y. Bidirectional branch and bound for controlled variable selection. Part II: Exact local method for self-optimizing control. *Computers Chem. Eng* **2009**, *33*, 1402–1412.
- (22) Di Ruscio, D. The Partial Least Squares Algorithm: A Truncated Cayley-Hamilton Series Approximation Used to Solve the Regression Problem. *Modeling, identification and control* **1998**, *19*, 117–140.
- (23) de Jong, S. SIMPLS: An alternative approach to partial least squares regression. *Chemom. Intell. Labor. Systems* **1993**, *18*, 251–263.
- (24) Butler, N. A.; Denham, M. C. The Peculiar Shrinkage Properties of Partial Least Squares Regression. *J. R. Stat. Soc.* **2000**, *B 62*, 585–593.
- (25) Lingjærde, O. C.; Christophersen, N. Shrinkage Structure of Partial Least Squares. *Scand. J. Stat.* **2000**, *27*, 459–473.

- (26) Helland, I. S. Some Theoretical Aspects of Partial Squares Regression. *Chemom. Intell. Labor. Systems* **2001**, 58, 97–107.